

## Central Station MONITOR REQUIREMENTS MATRIX

BUILDINGS 1960-2009 (revised as of May, 2011)

**NOTE: Any sprinklered building, post '81 with unrated corridors must have monitoring.**

Dates covered	Reference	Use Groups Central Stn Monitor Req'd	System type	Code Section
1960-1969	BOCA 1960 & 1965	H, A (>300), I-2	Sprinkler, fire alarm	1217.4 (see 1219 for interior alarms)
~1970 to Feb, 1976	BOCA 1970 w/ 1972 Supp.	A-3(>300), F1 w no windows H,I2	Sprinkler	1217.4,517.24
Feb, 1976 to Aug, 1978	BOCA 1975	A4,B(>=3st)I,R1 ,R2(>=5st)	Fire alarm	1218.2
Aug, 1978 to July, 1982	BOCA 1978	A4,B(>=3st),I, R1,R2(>=5st)	Fire alarm	1218.2
July, 1982 to April, 1986	BOCA 1981	A4,B(>=3st),I, R1(>=5st), R2(>=5st)	Fire alarm	1718.2
July, 1982 to April, 1986	BOCA 1981	Any: can lock valves open	Sprinkler	1718.1
Apr, 1986 to Mar, 1988	BOCA 1984	A,E,I,R	Sprinkler	1718.1
Apr, 1986 to Mar. 1988	BOCA 1984	A4,B(>=3st),E,I, R1(>=5st), R2(>=5st)	Fire alarm	1718.2
Mar, 1988 to Mar, 1991	BOCA 1987	A,E,I,R	Sprinkler	1020.1
Mar, 1988 to Mar, 1991	BOCA 1987	A4,B(>=3st)E,I, R1(>=5st), R2 (>=5st)	Fire alarm	1020.2
Mar, 1991 to Apr, 1994	BOCA 1990	A,B,E,I,M,R	Sprinkler	1020.1
Mar, 1991 to April, 1994	BOCA 1990	A4,B(>=3st),E, I,R1(>=5st), R2(>=5st)	Fire Alarm	1020.2
Apr, 1994 to Apr, 1997	BOCA 1993	A,B,E,H,I,M,R,	Sprinkler	923.1
Apr, 1994 to Apr, 1997	BOCA 1993	A4,B(>=3st),E,I, R1(>=5st),R2(>=5st)	Fire Alarm	923.2
Apr, 1997 to Oct. 1, 2003	BOCA 1996	A,B,E,H,I,M,R	Sprinkler	924.1
Apr, 1997 to Oct. 1, 2003	BOCA 1996	A4,B(>=3st)E,I, R1(>=5st),R2(>=5st)	Fire alarm	924.2

		<b>Central Stn Monitor req'd</b>		
Oct. 1, 2003 to Nov, 2005	IBC 2000	All use groups: central stn	Sprinkler	903.4
Oct. 1, 2003 to Nov, 2005	IBC 2000	A,B,E,F,H,I2,I3, M,R1,R2	Fire Alarm	907.14
Nov 16, 2005 to May 1, 2008	IBC 2003	All use groups: central stn	Sprinkler	903.4
Nov. 16, 2005 to May 1, 2008	IBC 2003	A,B,E,F,H,I2,I3, M,R1,R2	Fire Alarm	907.14
May 1, 2008 to present	IBC 2006	All use groups: central stn	Sprinkler	903.4
May 1, 2008 to Feb 28, 2011	IBC 2006	A,B,E,F,H,I2,I3, M,R1,R2	Fire Alarm	907.14
March 1, 2011 to present	IBC 2009	All use groups: central stn	Sprinkler	903.4.1
March 1, 2011 to present	IBC 2009	All use groups except S,U	Fire Alarm	907.6.5

Key: st = story; ">" = "greater than"; ">=" is defined as "greater than or equal to"; ed. = edition.

**All use groups have been translated into current code.**